



Top view

SECAD Aeration							
Product	Diffuser	Header Pipe	SS Grade				
A	9" SSI 2433, 5 mm orifice	110mm PVC	SS 304				
Zone	Product	Diffusers	Total Diffuser Area (m ²)	Nominal Header Spacing (mm)	Nominal Diffuser Spacing (mm)	Manifold	Zone Length
1	A	1000	38.09	535	310	250mm flange	17.01 m
2	A	1200	26.66	760	310	200mm flange	17.01 m

Disclaimer
 The accuracy of the output is based on the accuracy of the input data, and it is the responsibility of those supplying that information to verify that the data is correct. The drawing is supplied for reference only, based on FFG equipment, and is meant for preliminary pump design and system evaluation. A professional engineer, licensed in the appropriate field of engineering, should always conduct the final evaluation of the application if there are liabilities involved.

Designed by silran mizha	Checked by 08/08/2019	Scale Conceptual drawing	Revised
Drawn by	Date	Project	Sheet
Approved by			
		This document may not, without our permission, be copied, stored or made available to others or any other unauthorized person.	Scale 1:50
Author	Drawn by	ayalon 4026 Tank 1	

SECAD™ 5.2.6.6 (5.2) Standard

A1